



Government Of West Bengal
Office Of The Divisional Fire Officer, Jalpaiguri
West Bengal Fire & Emergency Services
Jalpaiguri Fire Station, Race Course Para,
P.O. & P.S. :- Jalpaiguri, Pin:- 735101

Memo no.:IND/WB/FES/20192020/53374

Date: 08-11-2023

From:

Divisional Fire Officer, Jalpaiguri
West Bengal Fire & Emergency Services

To: Himalayan International Residential School

Mouza- Sannasikata, Vill- Kalinagar, P.O. P.S.- Rajganj, Dist- Jalpaiguri, Pin- 735134.

Sub: Renewal of Fire Safety Certificate for occupancy of a G+II Storied Educational Building at Mouza- Sannasikata, Vill- Kalinagar, P.O. P.S.- Rajganj, Dist- Jalpaiguri, Pin- 735134.

This is in reference to your application no. 0125191237900191 dated 06-10-2023 regarding the Renewal of Fire Safety Certificate for occupancy of a G+II Storied Educational Building at Mouza- Sannasikata, Vill- Kalinagar, P.O. P.S.- Rajganj, Dist- Jalpaiguri, Pin- 735134.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

Recommendation:

1. Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the Driveway.
2. The Interior finish decoration of building shall be made with low flame spread material confirming to the I.S. Specification.
3. To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the building shall be strictly maintained.
4. Existing Electrical wiring of the whole building shall have to be carefully checked for anywhere and tear in them, particularly lines above false ceiling & ducts.
5. A Fire control room including a closed circuit T.V. system will have to be installed which observes all floors of the buildings.

6. The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all venerable places of the Building.
7. The employees and security staff shall be conversant with installed Fire Fighting equipment of the building and to operate in the event of Fire and Testing.
8. If required the old electrical line shall have to be replaced with new lines, the cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.
9. Mock Fire Practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.
10. A crew of trained Fireman under experienced officer shall be maintained round the clock for safety of the building.
11. First-Aid Fire Fighting system shall be provided as per I.S. Specification.
12. Arrangement shall have to be made for regular checking, testing, and maintenance of all the Fire Fighting installation in the Building to keep them in perfectly good working condition at all the times.
13. Periodical flashing of water in the Hydrants & Sprinkler Pipe line shall be made to maintain the efficient working performance of above mention system.
14. The Fire Safety audit to be conducted at regular interval and to be recorded in the Fire Prevention maintenance registers.
15. Any deviation and changes in the nature and use of the building in respect of the approved plan drawing without obtaining prior permission from this office, this fire safety certificate will be treated as cancelled
17. This Fire Safety Certificate' is valid for 3(three) year and has to be renewed thereafter from the date of issue of this letter.
18. After every three years a certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services regular performance of all the life & Fire Safety arrangements and installations of the building.

Signature valid

Digitally Signed:
Name: DEBTAJ DAS
Date: 09-Nov-2023 12:27
Reason: Approved
Location: West Bengal

Divisional Fire Officer, Jalpaiguri Division, Jalpaiguri
West Bengal Fire & Emergency Services