



**Government Of West Bengal**  
**Office Of The Divisional Fire Officer, Jalpaiguri**  
**West Bengal Fire & Emergency Services**  
**Jalpaiguri Fire Station, Race Course Para,**  
**P.O. & P.S. :- Jalpaiguri, Pin:- 735101**

Memo no.:IND/WB/FES/20192020/53374

Date: 08-04-2021

**From:**  
**Divisional Fire Officer, Jalpaiguri**  
**West Bengal Fire & Emergency Services**

**To: Himalayan International Residential School**  
**Mouza- Sannasikata, Vill- Kalinagar, P.O. P.S.- Rajganj, Dist- Jalpaiguri, Pin- 735134.**

**Sub: RENEWAL OF FIRE SAFETY CERTIFICATE FOR EDUCATIONAL BUILDING .**

This is in reference to your application no. 0125191217900040 dated 25-02-2021 regarding the RENEWAL OF FIRE SAFETY CERTIFICATE FOR EDUCATIONAL BUILDING .

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

**Recommendation:**

1. Driveway must be free of any type of obstruction for easy movement of Fire appliances. No parking will be allowed on the Driveway.
2. The Interior finish decoration of building shall be made with low flame spread material conforming to the I.S. Specification.
3. To eliminate risk of Fire Hazards, Good House keeping both for insides and outside of the building shall be strictly maintained.
4. Existing Electrical wiring of the whole building shall have to be carefully checked for anywhere and tear in them, particularly lines above false ceiling & ducts.
5. A Fire control room including a closed circuit T.V. system will have to be installed which observes all floors of the buildings.
6. The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all venerable places of the Building.
7. The employees and security staff shall be conversant with installed Fire fighting

The authenticity of this document can be verified by accessing the URL: [edistrict.wb.gov.in](http://edistrict.wb.gov.in) and then clicking on the 'Verification of Digitally Signed Document' link and keying in the Unique Number : 0125191217900040.

Page : 1

equipments of the building and to operate in the event of Fire and Testing.

8. Transformer and Switch Gear room shall be protected with automatic Co2 or D.C.P. Fire extinction confirming I.S. Specification.

9. If required the old electrical line shall have to be replaced with new lines, the cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.

10. Mock Fire Practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.

11. A crew of trained Fireman under experienced officer shall be maintained round the clock for safety of the building. First-Aid Fire fighting system shall be provided as per I.S. Specification.

13. Arrangement shall have to be made for regular checking, testing, and maintenance of all the Fire fighting installation in the Building to keep them in perfectly good working condition at all the times.

14. Periodical flashing of water in the Hydrants & Sprinkler Pipe line shall be made to maintain the efficient working performance of above mention system.

15. The Fire Safety audit to be conducted at regular interval and to be recorded in the Fire Prevention maintenance registers.

16. Any deviation and changes the nature of use of the building in respect of the approved plan drawing without obtaining prior permission from this office, this fire safety certificate will be treated as cancelled


17. One standby Pump need to be installed within six months (if not) along with the conditions as mentioned in the recommendation to ensure better safety from fire service point of view.

18. This 'Fire Safety Certificate' is valid for 3 (three) years only from the date of issue subject to the maintenance of the conditions as mentioned above as per fire service act.

Signature valid


Digitally signed by PRODIP  
SARKAR  
Date: 2021.04.08 13:55:03 IST

Divisional Fire Officer, Jalpaiguri  
West Bengal Fire & Emergency Services



Manager

Himalayan International Residential School



Principal

HIMALAYAN INTERNATIONAL RESIDENTIAL SCHOOL